

Government of Andhra Pradesh**A.P. State Disaster Response and Fire Services Department****Periodical Renewal Fire Certificate**

From:
Regional Fire Officer
Zone-2,Rajahmundry
Andhra Pradesh.

To:
District Educational Officer,

File No: 30698/KNS/RFO/2026, Date:13/03/2026

Occupancy NoC RC Number: File No.18948/KNS/RFO/2023, Dt.20/07/2023.

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **(SAMSIDH SCHOOL)**, represented by **(SAMSIDH SCHOOL)**, D.No.9-143, Anathavaram Village, Mummidivaram Mandal **Dr.B.R.Ambedkar Konaseema District.** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. File No.18948/KNS/RFO/2023, Dt.20/07/2023., Dt.20/07/2023
 4. Renewal NOC For Occupancy File No.18948/KNS/RFO/2023, Dt.20/07/2023., Dt.09/08/2024
 5. Online Application for Renewal NOC of (SAMSIDH SCHOOL), D.No.9-143, Anathavaram Village, Mummidivaram Mandal Dr.B.R.Ambedkar Konaseema District. - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 12-03-2026.

-- x --

The Management of (SAMSIDH SCHOOL), represented by (SAMSIDH SCHOOL), D.No.9-143, Anathavaram Village, Mummidivaram Mandal Dr.B.R.Ambedkar Konaseema District. has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.38628/- vide challan No. 91395702772025, Dated 09/03/2026 at CFMS, Online.

(SAMSIDH SCHOOL)

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **(SAMSIDH SCHOOL) D.No.9-143, Anathavaram Village, Mummidivaram Mandal Dr.B.R.Ambedkar Konaseema District.**, subject to the following conditions.

SI	As Builder	As Occupant	As Security Personnel
----	------------	-------------	-----------------------

1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 09/08/2025 to 08/08/2027.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
91395702772025	2026-03-09	38628

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.


The Inspection committee consists of DDRFO-Konaseema and FSI0-Mummadivaram has inspected the premisses and offered the remarks as : Recommended : Sir, Submitted that the building has Ground + Three upper floors with having 02 no's Staircases and provided Fire Fighting Equipment are in working condition sir Hence, the Inspection committee has recommended Renewal NOC.

“UNITE TO IGNITE, A FIRE SAFE INDIA”

“అగ్ని సురక్షిత భారతదేశానికీ ఐక్యమవ్వండి”



Your Sincerely,



Regional Fire Officer
Zone-2, Rajahmundry
Andhra Pradesh.

In case of emergency, please call 101 or 08856-271101 or 7989956542

Copy to (SAMSIDH SCHOOL), D.No.9-143, Anathavaram Village, Mummidivaram Mandal

Dr.B.R.Ambedkar Konaseema District.

Copy to Chief Office for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned